



AC156 Seismic Qualification Testing of Supertorque 8ZR Genset Starting Systems

Qualification Level:
S_{DS} = 2.00g, z/h = 1.0
S_{DS} = 2.50g, z/h = 0.0

Report Prepared For: **SENS**

Testing Conducted at:
Dynamic Certification Labs, 1315 Greg Street, Suite 109
Sparks, NV 89431

Shake Table Test Date: 3/12/25
Report Date: 3/20/25

Tested Equipment Manufactured and Provided by: **SENS**

Prepared By:

Nastya Veyngerova
Seismic Test Engineer

3/20/25
Date

Reviewed for Compliance with
AC156 and HCAI's PIN 55



Date: 03/24/2025

Reviewed By:

Rachel Wolfe
Seismic Test Engineer

3/20/25
Date



This test report shall not be reproduced except in full, without the written approval of the laboratory. The results herein relate only to the items received and tested for Project No. 08826-2401.

DCL Doc. R.1, Rev 5

Report # DCL-08826-2401-AC156-Rev0