

CERTIFICATE OF COMPLIANCE

Certificate Number 20160926-EX6409
Report Reference EX6409-20160923
Issue Date 2016-SEPTEMBER-26

Issued to: STORED ENERGY SYSTEMS
1840 INDUSTRIAL CIR
LONGMONT CO 80501-6524

**This is to certify that
representative samples of**

BATTERY CHARGERS FOR ENGINE-DRIVEN
EMERGENCY AND STANDBY POWER SYSTEM
GENERATORS

USL -Battery chargers for charging engine-starter batteries,
Model M, f/b 1, 3 or 4, f/b 12, 24 or 22, f/b 00, 06, 10, 12 or
15, f/b 00, 06, 10, 12 or 15, may be followed by additional
letters or numbers.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: Standard for Safety For Battery Chargers For Charging
Engine-Starter Batteries, UL 1236

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

