

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20160926-EX6409  
**Report Reference** EX6409-20160921  
**Issue Date** 2016-SEPTEMBER-26

**Issued to:** STORED ENERGY SYSTEMS  
1840 INDUSTRIAL CIR  
LONGMONT CO 80501

**This is to certify that  
representative samples of**

BATTERY CHARGERS FOR USE WITH INTERNAL  
COMBUSTION ENGINES DRIVING CENTRIFUGAL FIRE  
PUMPS

BATTERY CHARGERS FOR ENGINE-DRIVEN  
EMERGENCY AND STANDBY POWER SYSTEM  
GENERATORS

Battery chargers for charging engine-starter batteries,  
Model M, f/b 1, 3 or 4, f/b 12, 24 or 22, f/b 00, 10, 12 or 15,  
f/b 00, 06, 10, 12 or 15, may be followed by additional  
letters or numbers.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** Standard for Safety For Battery Chargers For Charging  
Engine-Starter Batteries, UL 1236

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

