



CERTIFICATE OF SEISMIC COMPLIANCE



This is to signify that
Stored Energy Systems (SENS)



1840 Industrial Circle
Longmont, CO 80501

has tested the following product per the referenced test standard, and passed functionality requirements:
Microgenius S2 & S4

Scope of Certification:

Product Type: Battery Chargers
Mfg Series/Make: Microgenius
Mfg Model: S2, S4
Mounting: Rigid/Isolated wall Mounted
Public Report No: P22987-Trans-01

Codes and Standards:

IBC 2009, 2012, 2015, 2018
ASCE 7-05, 7-10, 7-16
ICCES AC-156-2015

Maximum Design Loads:

$S_{Ds}(g) = 2.5$ $I_p = 1.5$
 $F_p/W_p = 1.88$ $z/h = 1.0$
Weight(lbs) = 32 $A_{FLXH} = 3.2$
Dimensions: 14.25x16.5x10.44 $A_{FLXV} = 1.68$

Test Lab: ETL, Dallas, TX

Qualification Agency: Petra Seismic Design

Notes:

Certification valid for testing compliance of units in scope. Equipment must be installed, mounted, seismically braced and anchored per mfg instructions. Equipment must only be used as intended. Certification verifies that representative product line units have been shake tested per referenced codes and standards and confirmed to function after the test. Certificate does not guarantee the equipment will remain compliant to other standards (i.e. ETL,UL, etc.) after a seismic event. See Public Report for complete explanation of qualification, limits, and requirements.

Certificate No.: SN01-COC-1801

Certificate date: May 25, 2018 Expires: May 25, 2019

Robert E Simmons, PE, CEO